

Note:

- Rumbled bricks may be wider than 70mm; if the cavity is the min.
 40mm, the bricks must overhang the outside edge of the rebate.
- Mortar joints 10mm ± 3, 6mm max rake (Hard-tooled concave joint preferred).

© 2019 Petros Holdings Ltd



MPT Stoneclad System Brick Veneer - Overhanging

Reference: MPT_S017

Date: September 2019

Scale: 1:4@A4

Revision: 2