

Note:

- Rumbled bricks may be wider than 70mm; if the cavity is the min. 40mm, the bricks must overhang the outside edge of the rebate.
- Mortar joints 10mm ± 3, 6mm max rake (Hard-tooled concave joint preferred).

2019 Petros Holdings Ltd		
Mineral	MPT Stoneclad System	Reference: MPT_S017
Plaster	Brick Veneer - Overhanging	Date: September 2019
Technology Hillside Rd, Wairau Valley ckland 0627		Scale: 1:4 @ A4
la Ub2/ aland inserted actor co. p.z. Phy 0800.25.23.678	Revision: 2	

TERMS OF USE Disclaimer: This information is intended solely as a guide for use of MPT products. Before using you should ensure that the product is suitable for use in the specific application. Nothing in this information constitues a statement of fitness for particular purpose and appropriate expert advice is to always be obtained. Petros Holdings Ltd makes no warranty regarding the use of this information. This drawing is the property of Petros Holdings Ltd. It must not be copied in any form except for the purpose of specifying the use of MPT products in construction projects.